

RESOLUTION NO. 747

A RESOLUTION ADOPTING LOCAL PRETREATMENT DISCHARGE LIMITS FOR PENN TOWNSHIP DISCHARGERS TO THE HANOVER REGIONAL WASTEWATER TREATMENT FACILITY.

WHEREAS, on August 3, 1983 the Board of Commissioners of Penn Township, York County, Pennsylvania (Township) entered into agreement with the Borough of Hanover (Borough), to transport and treat sewage originating within certain areas of each other's political subdivision, and

WHEREAS, the General Pretreatment Regulations (40CFR, Part 403) allows the Borough to establish specific pollutant limitations on users of its publicly owned treatment works, and

WHEREAS, users of the sanitary sewer system who are located in Penn Township, and whose sanitary sewer discharge terminates at the Hanover Area Wastewater Treatment Facility, are required to comply with the specified pollutant limitations established by the Borough, and

WHEREAS, the local discharge limits may be detailed in the user's wastewater discharge permit following approval of said limits by the U.S. Environmental Protection Agency.

NOW, THEREFORE, BE IT RESOLVED, that the Township of Penn hereby adopts the following allowable discharge limits for users of the Hanover Regional Wastewater Treatment Facility:

| <b>Pollutant<sup>1</sup></b> | <b>Current Local Limit<sup>2</sup> mg/L</b> | <b>Proposed Local Limit<sup>3</sup> mg/L</b> |
|------------------------------|---|--|
| Total Phosphorus             | 8.00  | -----  |
| Color <sup>4</sup>           | 75.00                                       | -----  |
| Antimony, Total              | 0.61  | 0.11   |
| Arsenic, Total               | 0.10  | 0.13   |
| Beryllium, Total             | 0.19  | 0.13   |
| Cadmium, Total               | 0.05  | 0.01   |
| Chromium, Total              | 3.30  | 3.30   |
| Chromium, Hexavalent         | 0.32  | 0.51   |
| Copper, Total                | 0.72  | 0.66   |
| Lead, Total                  | 0.38  | 0.21   |
| Mercury, Total               | 0.0002                                      | 0.0061                                       |
| Molybdenum, Total            | 0.09  | 0.46   |
| Nickel, Total                | 0.48  | 0.73   |
| Selenium, Total              | 0.13  | 0.18   |
| Silver, Total                | 0.71  | 0.29   |
| Zinc, Total                  | 0.6   | 0.47   |
| Cyanide, Total               | 0.19  | 0.27   |
| Naphthalene                  | 1.8   | 1.10   |
| Bis (2-ethylhexl) phthalate  | 0.12  | 0.08   |
| Phenols, Total               | 2.3   | -----  |


|                    |      |      |
|--------------------|------|------|
| Chloroform         | 0.08 | 0.10 |
| Ethylbenzene       | 1.6  | 1.66 |
| Methylene Chloride | 1.0  | 0.14 |
| Tetrachloroethene  | 1.1  | 0.05 |
| Toluene            | 8.5  | 2.07 |
| Trichloroethylene  | 0.12 | 0.03 |

Notes:

- (1) All Local Limits enforced as Maximum Daily limits.
- (2) As Adopted by the Borough in Ordinance No. 2010 on January 21, 1998.
- (3) As accepted by USEPA on September 30, 2010.
- (4) Color is reported in Platinum Cobalt (Pt-Co) units.


RESOLVED AND ENACTED this 20th day of December 2010.

Board of Commissioners of Penn Township

By: 

\_\_\_\_\_  
Craig M. Prieber, President

Attest:

  
\_\_\_\_\_  
Kristina J. Rodgers, Secretary